

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0981:109

Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Greenheck Fan Corp., 400 Ross Ave., Schofield WI 54476-0410
Contact: *Marty Gissel (715) 355-6611

DESIGN: Models SSDFD-21, SSFSD-21, SSFSD-22, SSFSD-23, OSSDFD-21, OSSFSD-21, OSSFSD-22 and OSSFSD-23 multi-blade fire dampers. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:	Models	<u>Single Sec.</u>		<u>Double Sec.</u>		<u>Rated</u>
		W	H	W	H	
	SSFSD-21/22/23	24"	30"	48"	30"	1-1/2 Hr
	SSDFD-21	24"	30"	48"	30"	1-1/2 Hr
	OSSDFD-21	24"	30"	NA	NA	1-1/2 Hr
	OSSFSD-21/22/23	24"	30"	NA	NA	1-1/2 Hr

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For vertical and horizontal installation except for Models OSSDFD-21, OSSFSD-21, -22, -23 are for vertical installation only.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as fire dampers for use as described under "Design" and "Installation".

NOTE: Refer to Listing No. 3230-0981:110 for leakage rated dampers.

*Rev. 05-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager